

Dr. R. Rudramoorthy
BE(Hons),ME,Ph.D

Principal



PSG COLLEGE OF TECHNOLOGY

Govt. Aided Autonomous College Affiliated to Anna University

Approved by AICTE and ISO 9001: 2000 Certified.

Established in 1951 (A unit of PSG & Sons' Charities)

Peelamedu, Coimbatore - 641 004. Phone : 91 422 2572177, 2572477, 4344777

Fax : 91 422 2573833, 91 422 4344377 Grams : 'CHARITY'

E-mail : principal@psgtech.ac.in, principal@psgtech.edu, Website : http://www.psgtech.edu

DEPARTMENT OF CIVIL ENGINEERING

Ref : P/SM/Test/LN555/2017/586

Date : 04.12.2017

Client : M/s. MAK INDIA LTD.,
7/41B, Avinasi Road
Civil Aerodrome
Coimbatore - 641 014.

Tested by : Mr T Ramesh

Reference : 1) Your Letter dated : 13.11.2017
2) Your letter dated : 28.11.2017


Client's letter and test : dt. 13.11.2017
specimens received on

Compression Test on Paver Blocks

Sl. No.	Ref.	Area (mm ²)	Ultimate Compressive Load (kgf)	Ultimate Compressive Stress (N/mm ²)
1	-	28800	76000	25.88
2	-	28800	72000	24.53
3	-	28800	70000	23.84
4	-	28800	74000	25.21
5	-	28800	71000	24.18
6	-	28800	69000	23.50


TEST IN-CHARGE


LAB IN-CHARGE




HoD of Civil Engineering